



Smog-Hog® Portable Electrostatic Precipitator Owner's Manual

Model PCN



ENGINEERING **YOUR** SUCCESS.

KNOW YOUR EQUIPMENT

READ THIS MANUAL FIRST.

Your Smog-Hog® PCN should provide many years of trouble-free service. This manual will help you understand the operation of your PCN unit. It will also help you understand how to maintain it in order to achieve top performance. For quick future reference, fill in the system and filter information in the spaces below. Should you need assistance, call the Parker customer service number shown below. To expedite your service, have the following information available when contacting Parker.

Unit Order #: _____

Unit Model #: _____

Unit Serial #: _____

System Accessories:

Installation Date: _____

Parker Hannifin Customer Service

1-800-343-4048

Table of Contents

Safety Precautions	iii
1. Introduction	1
1.1 Description and Operation	1
1.2 Electrical Characteristics	1
1.3 Specifications	1
2. Installation	2
2.1. Packaging	2
2.2 Inspection Note	2
2.3 Installing the Extraction Arm Assembly	2
3. Operation	3
3.1 Turning the Unit On	3
3.2 Operating the Unit	3
4. Maintenance and Cleaning	4
4.1 Cleaning Schedules	4
4.2 Component Cleaning	4
4.3 Periodic Maintenance	5
4.4 Other Maintenance	5
5. Troubleshooting Guide.....	6
5.1 How to Check High Voltage	7
5.2 Checking for Ionizer High Voltage	7
5.3 Checking for Cell High Voltage	7
5.4 Determining the Loss of High Voltage	8
5.5 Checking Air Movement (Blower and Drive)	9
6. Replacement Parts.....	9
6.1 Ordering Parts	9
6.2 Returning Parts	9
7. Troubleshooting Flowchart	10
8. PCN Parts List.....	11
9. Wiring Diagram	12

SAFETY PRECAUTIONS

We have provided many important safety messages in this manual and on the PCN Electrostatic Precipitator. Always read and obey all safety messages.

This is the safety alert symbol.



This symbol alerts you to potential hazards that can kill or hurt you and others. All safety messages will follow the safety alert symbol and the word “DANGER”, “WARNING”, or “CAUTION”. These words mean:



DANGER

Indicates a hazardous situation which, if not avoided, will result in death or serious injury.



WARNING

Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.



CAUTION

Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury.

CAUTION

CAUTION used without the safety alert symbol indicates a potentially hazardous situation which, if not avoided, may result in property damage.

IMPORTANT SAFETY INSTRUCTIONS

WARNING

To reduce the risk of fire, electric shock, or injury when using your air cleaner, follow these basic precautions:

- Wear protective clothing and safety glasses when handling collector components or servicing the unit.
- Use proper lifting and rigging equipment to install your electronic precipitator.
- The electronic precipitator should be properly grounded prior to servicing.
- Disconnect power before servicing.
- Replace all access panels before operating.
- Do not operate the unit with component doors open.
- Electrical connections should only be made by qualified personnel and be in accordance with local and national codes and regulations.
- Do not use in explosive atmospheres.
- Do not collect emissions which are explosive
- Use non flammable cleaners.
- Keep flammable materials and vapors, such as gasoline, away from unit.
- The unit should be inspected frequently and contaminants removed to prevent excessive accumulation which may result in flash-over or fire damage.
- Operate only in a safe and serviceable condition.
- Operating temperature to the air stream should not exceed 120° F.

COMBUSTIBLE DUST HAZARDS – SMOG-HOG® and DUST-HOG® Pollution Control Systems

Pursuant to National Fire Protection Agency (NFPA) Standards, the owner/user is required to test their dust mixtures to evaluate and understand potential combustion or deflagration hazards that may exist. In addition, NFPA standards require the owner/user to perform and have record of a Dust Hazard Analysis (DHA) if there is potentially a combustible material involved within or exposed to the process.

The DHA serves as a systematic review of the process to:

- 1) Identify where fires and explosions can occur;
- 2) Identify the potential causes and consequences, and;
- 3) Determine if existing and proposed safeguards are sufficient.

It is the responsibility of the owner/user to evaluate, interpret and document any associated risk in their process including adherence and compliance to any and all applicable local, state and federal codes, standards, laws and regulations.

It is the sole responsibility of the equipment owner/user of record to coordinate and perform sample material collection and combustion/explosivity testing of any and all dust and material that will be extracted and filtered by the Air Pollution Control (APC) filtration equipment and to notify Parker of the results prior to any discussion involving equipment specification and solution recommendation. It is recommended to utilize a Certified Industrial Hygienist (CIH) or certified safety expert that is properly trained, licensed and approved and to use a licensed and approved dust testing facility for proper dust and material analysis, testing protocol and reporting procedures. A sample of testing facilities and list of Industrial Hygiene (CIH) and other occupational and environmental health and safety (OEHS) consultants can be located through AIHA (American Industrial Hygiene Association) website.

To minimize the risk of fire or explosion, user must ensure proper installation, operation and maintenance of Parker equipment. Since application, installation, operation and maintenance are beyond the control of Parker, Parker disclaims any liability or responsibility for damage from fires or explosions regardless of origin. Parker recommends that all APC dust collection equipment, installation and application conform to any and all applicable local, state and federal standards, codes, laws and regulations including the addition of appropriate fire or explosion protection systems including but not limited to venting, mitigation, suppression and isolation when and where required. Installation of Parker equipment should be by a licensed contractor that is also experienced in potential fire and explosion hazards and adheres to related local, state and federal codes, standards, laws and regulations. Parker is not an expert nor certified design consultant in relation to spark, fire or explosion mitigation including but not limited to detection, mitigation, suppression and isolation of combustible dusts and materials. Therefore, Parker recommends that any industrial air filtration system recommendation, design or solution be reviewed, approved, stamped and signed by an industry expert consultant in air filtration systems, combustible dust/materials or certified safety expert such as a Certified Industrial Hygienist (CIH) or a Certified Professional Engineer (PE) who is a licensed and certified expert with industrial filtration system design and application including adherence and compliance to any and all applicable local, state and federal codes, standards, laws and regulations.

Pursuant to Parker's Offer of Sale (terms and conditions) and by accepting the purchased equipment, Buyer and owner/user agree to defend, indemnify, and hold harmless Parker, its successors, assignees, suppliers, shareholders, directors, officers, employees, agents, and affiliated companies from all losses, costs, damages, demands, claims, liabilities, fines, penalties or any other expenses (including attorneys' fees, court costs, and expert fees) (collectively "losses"), caused or contributed to in any way by Buyer or owner/user's failure to follow these instructions and/or failure to properly install, apply, operate, or maintain the equipment purchased from or supplied by Parker, or losses caused or contributed to in any way by Buyer's and owner/user's failure to provide accurate information, specifications or dust explosivity values.

Page intentionally left blank

1. Introduction

1.1 Description and Operation

The Smog-Hog PCN is a portable electronic air cleaner designed to eliminate particulate as it is generated.

Contaminant is captured at its source by a unit-mounted hood, then conveyed through a duct network to the precipitator where it is collected. Clean air is then re-circulated back to the work area.

As air approaches the precipitator, it passes through a reusable, aluminum mesh mechanical pre-filter which aids air distribution and removes large particles.

Pre-filtered air then passes through an ionizer where particles are charged by corona discharge from a series of small diameter charged tungsten wires centered between grounded plates. Particles then pass through a collection cell, consisting of alternately charged and grounded parallel aluminum plates. Charged plates at the same polarity as the charged particles repel the particles toward the grounded plates which, in turn, attract the particles. Air next passes through a centrifugal blower where it is exhausted vertically through an adjustable outlet grille, back to the work space.

An integrally mounted power pack converts 115 volt, single-phase AC power to the high voltage DC required for ionizer and collection cell operation.

1.2 Electrical Characteristics

The unit is rated for 115 VAC (volts alternating current), single phase, 60 Hz operation, or 3 phase. It has a 10' power cord with grounded plug and internal high voltage wiring.

1.3 Specifications

Power Requirements	115V, v 1/2 HP single phase, 60 Hz*, 8.1 amps 115V, 1 HP, 12.7 amps
Precipitator Voltage	Ionizer: 11,000 volts DC Collection Cell: 6,000 volts DC
Motor	1/2 HP or 1 HP, totally enclosed
Weight	400 lbs. (181 Kg)
Overall Dimensions (L"xW"xH")	42"x28"x44" (107x71x112 cm)
Cabinet	16 gauge steel
Air Cleaning Capacity	1,000 CFM** (1699M ³ H)
Capture Distance	18" (45.7 cm) max. recommended
Swing Arm Reach	132", 360° radius
Duct	8" diameter x 7", 10", 12"
Hood Size	8" diameter
Wheels	Two 8" (20.3 cm) wheels and two 5" (12.7 cm) swivel locking casters

*50 Hz optional

** Factory set. Nominal airflow rating

3 Phase

	208V	230V	460V	575V
1/2 HP	2.2	2.1	1.0	.9
1 HP	3.6	3.4	1.7	1.5

2. Installation

2.1 Packaging

The Smog-Hog PCN is shipped in three containers. One consists of the main cabinet and operating components. The second is the factory-assembled extraction arm with duct in place. The third is the hood.

2.2 Inspection Note

Upon receipt of your unit, check for any shipping damage. A damaged carton indicates that the equipment may have received rough handling during shipping that may have caused possible internal damage. Notify your delivery carrier and enter a claim if any damage is found.

2.3 Installing the Extraction Arm Assembly

The top of the PCN cabinet has eight 3/8-16 threaded inserts in the cabinet, and equally spaced around the air entry opening. The mating extraction arm mounting flange is ready for installation, and the mounting hardware (bolts, flat washers, and split ring lock washers) is in a plastic bag inside the main cabinet. The extraction arm assembly is approximately 50 lbs, but because of its size, may be best positioned by two people. The extraction arm support spring is in place on the assembly, with a protective shipping retainer box strapped in place (these must be removed before operating the unit). All pivot points are tightened slightly to keep arms from moving during handling. This assembly is shipped for installation so that the arm nearest the cabinet is in the vertical position when the bearing flange is being bolted down. With this arm extending up from the top of the cabinet, a ceiling height of about 10' is required for adequate clearance. Refer to the SA Installation and Owner's Manual for instructions on assembling the extraction arm or making field adjustments.



CAUTION

Sharp pulls on the arm or hood should be avoided since damage to the arm components could result.

3. Operation



CAUTION

Do not use the PCN where high concentrations of flammable materials may be present.
If in doubt, consult Parker.

3.1 Turning the Unit On

The PCN is provided with 10' of pre-wired type 3-SJ electrical cord with a three-prong male plug.

To operate the unit:

1. Plug the unit into a grounded 115V/1/60 Hz electrical receptacle.
2. For 3-phase units please refer to wiring diagram.
3. Lock wheel casters on unit to secure location.



CAUTION

Do not attempt to move the PCN unit by pulling on the extraction arm or hood.
Use handles on the back of the unit to pull the PCN around the work area.

4. Turn the unit on by flipping the toggle switch to the "on" position. The indicator lamp should glow, and the unit's drive fan should rotate. If either of these do not function, refer to the Troubleshooting section within this manual.
5. The unit is now ready for use.

3.2 Operating the Unit

The PCN moves 1,000 CFM of contaminated air away from the source of generation.

For good contaminant capture, a few simple guidelines apply:

1. Locate the unit, arm and hood in anticipation of the job(s) intended. Know the limitations of the unit and the job.
2. Minimize the influence of cross drafts from outside air sources.
3. Position the hood slightly higher than the source, with the face of the hood approximately 45° from horizontal. The hood shape is designed for high velocity pick-up. It should be located no further than 18" from the contaminant source.

4. Maintenance and Cleaning

4.1 Cleaning Schedules

To maintain maximum efficiency, use the following suggested cleaning schedules:

1. Weld Smoke

- Weekly: Using compressed air, gently blow components with high velocity air. Be careful not to damage plates.
- Monthly: Soak components using instructions outlined below. Collected contaminant varies greatly from one application to another, so cleaning frequency should be monitored and adjusted to maintain unit efficiency.
- The collecting pan should be emptied before dust reaches the top of the pan's internal baffles. Failure to do so will cause re-entrainment of previously collected dust into the airstream.

2. Oil Smoke

- Clean as required. When components become dirty, the indicator light will dim, and arcing of components will become frequent. Smoke may become visible from the PCN exhaust. Soak cleaning of components (see instructions below) at least every three months is recommended.
- The collecting pan should be emptied as required to prevent overflow.

4.2 Component Cleaning

1. Turn off the PCN and depress both push-to-test buttons to remove residual charge from the components.
2. Open the door and slide components out of the cabinet. If the collected particulate is dry, gently tap the components to remove loose particles. Components can be cleaned by soaking in a hot solution of industrial-grade cleaner that is safe for use with the aluminum components in the PCN.

It is extremely important to thoroughly wipe clean all high-voltage insulators whenever the components are cleaned. Use a non-abrasive cloth to protect glaze on the ceramic insulators.

For inorganic (e.g., iron oxide from welding) residue removal, acidic-type cleaners with a pH from 1 to 1.5 are most efficient. To clean organic (most petroleum-base oils) materials, alkaline base detergents with pH from 10 to 12 are effective. Consult your supplier for specific recommendations and application instructions. Any cleaner must contain an aluminum inhibitor or be otherwise made safe for use with aluminum.



CAUTION

Do not use temperatures exceeding 160° F. Do not steam clean, as this may cause the aluminum plates to warp. If detergent other than Smog-Hog brand is used, care must be taken to ensure that it contains an inhibitor so that it does not attack the aluminum components.

Let the aluminum components soak for approximately 30 minutes, followed by agitation in the solution to remove loosened dirt. If agitation is not possible, soak time should be increased to compensate.

3. After removing components from the detergent bath, immediately flush away any residue and rinse thoroughly with hot water.
4. Shake off excess water and let components stand in vertical position until they are dry to the touch.
5. Re-install components into the PCN cabinet, close the door and turn unit on. If the unit crackles excessively, or the indicator light fails to come on, open the access door and continue to run the blower to allow the components to dry thoroughly.




Figure 1
Motor/Blower Assembly




Figure 2
Ionizer Wire/Spring Installation

4.3 Periodic Maintenance

1. At least every three months (or whenever components are removed for soak cleaning), wipe clean the ionizer and collection cell contact springs and insulators located above the pre-filter. Clean out the interior cabinet area.
2. With the PCN unplugged, brush clean all wiring connections at the power pack and switches.
3. Check for drive belt tension and wear. One half inch movement (with finger pressure) at the belt mid-point indicates correct tension. Refer to Figure 1.

4.4 Other Maintenance

Instructions for replacing an ionizer wire:

1. Remove the damaged wire from each spring.
2. Replace spring if damaged.
3. Loop one end of the new wire over the bottom spring, pull down top spring with pliers and loop the top end of the wire over the spring hook. Refer to Figure 2.
4. Release the spring gently. The wire is now taut and automatically centered.

Note: In the event replacement wire is not immediately available, remove broken wire and springs from the assembly to allow operation until new parts can be installed.



CAUTION

The following section is for the use of trained service personnel only. The following procedures will expose hazardous live and moving parts. Disconnect the air cleaner before proceeding.

5. Troubleshooting Guide

Tools Required

1. Screwdriver: 8" or longer with insulated handle.
2. Volt-Ohmmeter: used to check low voltage input (120 VAC) and continuity (OHMS).
3. High Voltage Probe: used to check high voltage power supply, minimum range from 0-15 KVDC.

*Refer also to the Troubleshooting Flow Chart on page 10.

Normal Operation

1. Turning the toggle switch on allows power supply to the blower and high voltage power pack (see Wiring Diagram, page 12).
2. The indicator light is on, and its glow is bright and steady, indicating high voltage is present at the power pack.
3. Air draw through the welding hood to the PCN unit is adequate.
4. Unit is clean.

Abnormal Operation

1. The indicator light is off even though the unit blower is running.

Possible Cause:

- a. The light bulb is burnt out.
- b. The high voltage power pack is defective.
- c. A dead short exists in the ionizer and/or collection cell circuit.
- d. Components need cleaning.

Corrective Action:

- a. Replace the bulb.
- b. Replace the high voltage power pack.
- c. Troubleshoot and remove the short (see how to troubleshoot ionizer and cell circuit, page 7).
- d. Remove components and clean.

2. Indicator light is flickering on/off with audible arcing inside the cabinet.

Possible Cause:

- a. An intermittent short exists in the ionizer and/or cell circuit.
- b. Components need cleaning.

Corrective Action:

- a. Remove the ionizer and cell, inspect for the cause.
- b. Remove components and clean.

3. The indicator light is on but the unit does not have adequate air movement.

Possible Cause:

- a. The drive belt is loose or off the pulley.
- b. The drive motor has malfunctioned.
- c. The hood throat screen has plugged.
- d. Components need cleaning.
- e. The diffuser screen has plugged.

Corrective Action:

- a. Tighten or replace the belt.
- b. Repair or replace the motor.
- c. Remove the blockage from the screen.
- d. Remove and clean the components.
- e. Clean the diffuser screen.

4. The indicator light and the unit blower are both off.

Possible Cause:

- The toggle switch is in the "off" position.
- The unit does not have voltage input.
- The door safety switch on the inside of the collection component access door is defective or not activated.
- The access panel safety switch, located behind the blower access panel, is defective or not activated.
- Cabinet internal wiring has an open circuit.

Corrective Action:

- Reset the toggle switch.
- Determine the cause of input voltage loss.
- Re-activate the safety switch or replace the defective switch.
- Activate the safety switch or replace the defective switch.
- Determine the location of the open circuit and correct.

5.1 How to Check High Voltage

The indicator light on the unit will be on high if high voltage is present at the cell and ionizer terminals on the power pack. If the light is out, either the voltage applied to the components is below a good operating level or the light circuit is not functioning.

CAUTION

If push-to-test buttons are not depressed, a residual DC voltage will remain on the high voltage components for a short period of time after the access door is opened. To ensure safe handling, components should be grounded to the cabinet by means of an insulated handle screwdriver.

5.2 Checking for Ionizer High Voltage

(See Figure 3)

- Connect the ground wire on the handle of high voltage probe to the edge of the collection cell or other convenient cabinet ground.
- Place probe tip on the ionizer wire support rod.
- Depress the door safety switch to activate the power supply. The voltage through the ionizer should read approximately 11.0 KVDC.

5.3 Checking for Cell High Voltage

(see Figure 4)

- Connect the ground wire on the handle of high voltage probe to the edge of the collection cell.
- Place the tip of the probe at the center (metal support rod end) of the cell insulator.
- Depress the door safety switch to activate the power supply.
- The voltage through the cell should read 5 to 6 KVDC.





Figure 3
Ionizer High Voltage Check

5.4 Determining the Loss of High Voltage

As components build up dirt, the indicator light dims then goes out at a point approximately 3.5KV cell voltage. If satisfactory operating voltage is present at the ionizer and cell and the light is out, the problem is either a defective indicator light or light circuit.

If no voltage is present at the cell, and the indicator light is out:



1. Remove the cell and depress the door interlock switch.
2. If the indicator light comes on, the problem is in the cell. Check for the following:
 - a. Excessive build up between cell plates.
 - b. Something lodged between the cell plates, bowed or bent plates, etc.
 - c. Cracks in any of the eight cell insulators, carbon tracking or other insulator damage.
3. If the indicator light remains off with the cell out of the unit, remove the ionizer and activate the power supply.
4. If the indicator light comes on, the problem is in the ionizer. Check for the following:
 - a. Broken or loose ionizer wires.
 - b. Excessive build up on insulator(s).
 - c. Cracked or broken insulator(s).
5. If the light remains out with both the ionizer and cell removed, remove the side access panel and check out the high voltage power pack. See Figure 5.
 - a. Remove both high voltage leads from the end of the power pack.
 - b. Measure high voltage (use probe) at terminal No. 8 (output to ionizer) and terminal No. 7 (output to collector).
 - c. If no voltage is present or voltage is below minimum, replace the power pack.
 Note: Minimum reading with high voltage wires removed: 11KV at terminal No. 8 (ionizer) and 5KV at terminal No. 7 (collector).
6. If voltage is present and within limits, check for:
 - a. Short in the high voltage lead wires.
 - b. Cracked or broken cabinet insulators.

5.5 Checking Air Movement (Blower and Drive)

1. If the unit has deficient airflow:
 - a. Check for any type of restriction in the pick-up hood, flex hose or main unit.
 - b. Remove the pre-filter, cell and ionizer components and check for an obstruction at the diffuser plate directly above them. If none is present, check the components for excessive dirt build up.
 - c. If components are clean, remove the side access panel and check for:
 - i. Loose or broken belt
 - ii. Defective drive motor
 - iii. Loose pulley

CAUTION

The belt should have approximately 1/2" of play when depressed with one finger. Having the belt set too loose causes slippage and reduces airflow. Having the belt set too tight causes an over current condition in the motor. The resulting higher temperature shortens motor winding and bearing life.




Figure 5
Power Pack Terminal Connections

6. Replacement Parts

6.1 Ordering Parts


Replacement parts can be ordered from your local representative or from Parker direct. To order parts from Parker, contact Customer Service at 1-800-348-4048. Please have the following information available for prompt service:

1. Unit model number (on nameplate, blower access door)
2. Unit serial number (on nameplate, blower access door)
3. Part number of part(s) (see parts list)

6.2 Returning Parts



When returning a defective part under warranty, you need to call Parker Hannifin for a Return Material Authorization (RMA) number. This control number assures you receive prompt service, so it should appear prominently on the package being returned.

7. Troubleshooting Flowchart



*ILLUMINATED LIGHT INDICATES HIGH VOLTAGE PRESENT

9. Wiring Diagrams



Product Warranty – SMOG-HOG® and DUST-HOG® Pollution Control Systems

1. Subject to the terms and conditions hereof, Parker-Hannifin Corporation (PARKER) warrants that major structural components on MCB, PNP, SDC, SFC, and SHM series will be free from defects in materials and workmanship for ten (10) years from the date of shipment from Parker. Subject to the terms and conditions hereof, warrants to the original Buyer of any Parker product (PRODUCT) installed and used as recommended by PARKER in normal service, that if the PRODUCT fails or is materially defective within twenty-four (24) months from date of installation or thirty (30) months from the date of shipment (whichever is earlier), of such PRODUCT, then PARKER, at PARKER'S sole option, will replace the PRODUCT with the same or equivalent PRODUCT, repair the PRODUCT or refund the original purchase price for the PRODUCT. Such replacement, repair or payment by PARKER shall be in complete satisfaction of any and all liability of PARKER and its agents with respect to such PRODUCT. Excluded from any Parker warranty are hose, electrical motors or consumable products such as flexible hose, belts, filter cartridges, filter media, ESP cells, electrical components, gasketing, or any component defined by PARKER as a consumable item.

2. Parker IGFG's warranty policy covers defects that are due to manufacturing quality. Equipment must be installed, commissioned and maintained in accordance with Parker IGFG recommendations as documented in the specific user manual related to your dust or wet collector product. This warranty does not cover defects due to poor environmental conditions, improper installation, or wear and tear items. This warranty shall be void in case of:

- a) Any buyer's modifications not explicitly approved by Parker IGFG Division,
- b) Misuse or failure in maintenance - not in accordance with Parker's product recommendations,
- c) Use of unauthorized or non-genuine Parker replacement parts,
- d) Damage caused by corrosion, abrasion, abnormal use or misuse, misapplication, or normal wear and tear,
- e) Equipment not properly installed, operated and maintained under normal conditions and recommended applications.

As Buyers exclusive remedy for any defects in the equipment, Parker will exchange or repair any defective parts during the warranty period, provided such parts are returned, prepaid, to Parker factory. The obligation of Parker is limited to furnishing replacement parts EXW Parker factory or making repairs at Parker factory of any parts that are determined, upon inspection by Parker, to be defective. In no event will Parker be responsible for labor or transportation charges for the removal, reshipment or reinstallation of the parts. Replacement parts will be provided via INCOTERMS EXW from Parker's Lancaster NY location. Parker makes no warranty as to goods manufactured or supplied by others.

3. THE FOREGOING IS THE ONLY WARRANTY, GUARANTEE OR REPRESENTATION OF ANY KIND MADE WITH RESPECT TO THE SUBJECT PARKER PRODUCTS. NO IMPLIED WARRANTY, INCLUDING ANY IMPLIED WARRANTY OF NONINFRINGEMENT, DESIGN, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, APPLIES TO THE PRODUCT, AND NO OTHER EXPRESS WARRANTY OR GUARANTY, EXCEPT AS MENTIONED ABOVE, GIVEN BY ANY PERSON, FIRM OR CORPORATION WITH RESPECT TO THE PRODUCT SHALL BIND PARKER. PARKER SHALL NOT BE LIABLE FOR LOSS OF REVENUES OR PROFITS, EXPENSE FOR SUBSTITUTE EQUIPMENT OR SERVICE, STORAGE CHARGES, OR ANY OTHER SPECIAL, INCIDENTAL OR CONSEQUENTIAL DAMAGES CAUSED BY THE USE, MISUSE OR INABILITY TO USE THE PRODUCT REGARDLESS OF THE LEGAL THEORY ON WHICH THE CLAIM IS BASED, AND EVEN IF PARKER HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. NOR SHALL RECOVERY OF ANY KIND AGAINST PARKER BE GREATER IN AMOUNT THAN THE PURCHASE PRICE OF THE PRODUCT SOLD BY PARKER AND CAUSING THE ALLEGED DAMAGE. WITHOUT LIMITING THE FOREGOING, YOU ASSUME ALL RISK AND LIABILITY FOR LOSS, DAMAGE OR INJURY TO YOU AND YOUR PROPERTY AND TO OTHERS AND THEIR PROPERTY ARISING OUT OF USE, MISUSE OR INABILITY TO USE THE PRODUCT NOT CAUSED DIRECTLY BY THE NEGLIGENCE OF PARKER. THIS LIMITED WARRANTY IS GIVEN ONLY WITH RESPECT TO A PRODUCT PURCHASED FROM PARKER OR AN AUTHORIZED PARKER DISTRIBUTOR.

4. IN NO EVENT IS PARKER LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES ARISING OUT OF, OR AS THE RESULT OF, THE SALE, DELIVERY, NON-DELIVERY, SERVICING, NONCOMPLETION OF SERVICES, USE, LOSS OF USE OF, OR INABILITY TO USE THE PRODUCT OR ANY PART THEREOF, LOSS OF DATA, IDENTITY, PRIVACY, OR CONFIDENTIALITY, OR FOR ANY CHARGES OR EXPENSES OF ANY NATURE INCURRED WITHOUT PARKER'S WRITTEN CONSENT, WHETHER BASED IN CONTRACT, TORT OR OTHER LEGAL THEORY. IN NO EVENT SHALL PARKER'S LIABILITY UNDER ANY CLAIM MADE BY BUYER EXCEED THE PURCHASE PRICE PAID FOR THE PRODUCT.

5. Defective PRODUCTS must be documented via PARKER support "Case Number" within thirty (30) days after the date of the alleged failure or defect and within the warranty period by contacting Parker Technical Support via email or phone:

smoghog@parker.com or dusthog@parker.com
800-343-4048, option 2

The claim must specify in reasonable detail:

- 1) Product Serial Number or Parker Sales Order # and approximate Date of Purchase;
- 2) Where or from whom the product was originally purchased;
- 3) Description of problem symptom;
- 4) Description of troubleshooting effort details;
- 5) Description of physical location and/or environment details. The Buyer shall cooperate with PARKER in its investigation and provide full information and documentation concerning the PRODUCT and its usage.

Upon receipt of the claim, Parker IGFG will review and determine if the parts replaced need to be returned for quality evaluation and root cause investigation. If a part is required to be returned, Parker IGFG will issue a Return Material Authorization (RMA) to Return via email. Parts should be returned to Parker IGFG, freight collect, within 45 days accompanied by the RMA packing slip placed on the package. If the repaired part does not need to be returned you will be advised to field scrap it and the claim will be processed. Proof of the defect (written description and pictures of the parts units in question) is required.

NOTE: ANY PART NOT RETURNED WITHIN THE REQUIRED 45 DAYS WILL NOT BE REIMBURSED ON THE CLAIM.

On claims that require repaired parts return, the claim will be processed after the part has been evaluated by the Parker IGFG Quality Department for verification of failure mode. The claims will be paid in the form of a credit to the customer's account. Parker reserves the right to withdraw any quotation or proposal or reject any purchase order without liability.

Worldwide Filtration Manufacturing Locations

North America

Compressed Air Treatment

Industrial Gas Filtration and
Generation Division
Lancaster, NY
716 686 6400
www.parker.com/igfg

Haverhill, MA
978 858 0505
www.parker.com/igfg

Engine Filtration

Racor
Modesto, CA
209 521 7860
www.parker.com/racor

Holly Springs, MS
662 252 2656
www.parker.com/racor

Hydraulic Filtration

Hydraulic & Fuel Filtration
Metamora, OH
419 644 4311
www.parker.com/hydraulicfilter

Laval, QC Canada
450 629 9594
www.parkerfarr.com

Velcon
Colorado Springs, CO
719 531 5855
www.velcon.com

Process Filtration

domnick hunter Process Filtration
SciLog
Oxnard, CA
805 604 3400
www.parker.com/processfiltration

Water Purification

Village Marine, Sea Recovery,
Horizon Reverse Osmosis
Carson, CA
310 637 3400
www.parker.com/watermakers

Europe

Compressed Air Treatment

domnick hunter Filtration & Separation
Gateshead, England
+44 (0) 191 402 9000
www.parker.com/dhfn

Parker Gas Separations
Etten-Leur, Netherlands
+31 76 508 5300
www.parker.com/dhfn

Hiross Zander
Essen, Germany
+49 2054 9340
www.parker.com/hzfd

Padova, Italy
+39 049 9712 111
www.parker.com/hzfd

Engine Filtration & Water Purification

Racor
Dewsbury, England
+44 (0) 1924 487 000
www.parker.com/rfde

Racor Research & Development
Stuttgart, Germany
+49 (0)711 7071 290-10

Hydraulic Filtration

Hydraulic Filter
Arnhem, Holland
+31 26 3760376
www.parker.com/hfde

Ujala, Finland
+358 20 753 2500

Condition Monitoring
Parker Kittiwake
West Sussex, England
+44 (0) 1903 731 470
www.kittiwake.com

Process Filtration

domnick hunter Process Filtration
Parker Twin Filter BV
Birtley, England
+44 (0) 191 410 5121
www.parker.com/processfiltration

Asia Pacific

Australia
Castle Hill, Australia
+61 2 9634 7777
www.parker.com/australia

China
Shanghai, China
+86 21 5031 2525
www.parker.com/china

India
Chennai, India
+91 22 4391 0700
www.parker.com/india

Parker Fowler
Bangalore, India
+91 80 2783 6794
www.johnfowlerindia.com

Japan
Tokyo, Japan
+81 45 870 1522
www.parker.com/japan

Korea
Hwaseon-City
+82 31 359 0852
www.parker.com/korea

Singapore
Jurong Town, Singapore
+65 6887 6300
www.parker.com/singapore

Thailand
Bangkok, Thailand
+66 2186 7000
www.parker.com/thailand

Latin America
Parker Comercio Ltda.
Filtration Division
Sao Paulo, Brazil
+55 12 4009 3500
www.parker.com/br

Pan American Division
Miami, FL
305 470 8800
www.parker.com/panam

Africa
Aeroport Kempton Park, South Africa
+27 11 9610700
www.parker.com/africa

